

Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
 Wisconsin State Laboratory ID# 105-10117
 Wisconsin DNR Lab ID#399073400

X No samples were subcontracted; or the above test result(s) with '***' designation were produced by a subcontracted laboratory. [Laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

Client: Musser Environmental
 Bert Raney Elementary School
Address: 24594 Upsala Lane
 Hutchinson, MN 55350

Report Number: 16-05143
Sample Collection Date: 04/06/16
Sample Collection Time: 8:55
Sample Receipt Date: 04/06/16

Twin City Water Clinic Inc.
617 13th Avenue South
Hopkins, MN 55343
Phone: (952)935-3556

Sample ID	Analyte	Sample Location	Parameter	Sample Prep		Sample Analysis		Test	
				Date	Time	Date	Time	Results	Units
16-05143	Lead	1st Floor East	Drinking Water	04/06/16	15:25	04/07/16	10:06	<2.0	µg/L
16-05144	Lead	1st Floor West	Drinking Water	04/06/16	15:25	04/07/16	10:10	<2.0	µg/L
16-05145	Lead	2nd Floor East	Drinking Water	04/06/16	15:25	04/07/16	10:14	<2.0	µg/L
16-05146	Lead	2nd Floor West	Drinking Water	04/06/16	15:25	04/07/16	10:46	<2.0	µg/L
16-05147	Lead	Office Sink	Drinking Water	04/06/16	15:25	04/07/16	10:59	<2.0	µg/L
16-05148	Lead	Kitchen Sink	Drinking Water	04/06/16	15:25	04/07/16	11:10	6.19	µg/L

Approved methods used in analyzing the samples listed above have the following reporting levels:
 SM3113 - Lead, 2.0 µg / L
 Maximum contaminant levels: Lead, 15.0 µg / L

Sample Temp: 20 °C

Sample Collected by: Client TCWC
 Date Reported: 04/07/16

Approved By:  
 Laboratory Manager Senior Analyst

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.