

Twin City Water Clinic Laboratory Test Report

Minnesota State Laboratory ID# 027-053-119
 Wisconsin State Laboratory ID# 105-10117
 Wisconsin DNR Lab ID#399073400

X No samples were subcontracted; or the above test result(s) with '**' designation were produced by a subcontracted laboratory. [Laboratory name; address; MDH Lab ID#]. The subcontracted laboratory maintains MDH Certification for the field(s) of testing performed.

Client: Musser Environmental
 Yellow Medicin East P.S.
Address: 24594 Upsala Lane
 Hutchinson, MN 55350

Report Number: 16-13152
Sample Collection Date: 09/14/16
Sample Collection Time: 6:07
Sample Receipt Date: 09/20/16

Twin City Water Clinic Inc.
 617 13th Avenue South
 Hopkins, MN 55343
 Phone: (952)935-3556

Laboratory Sample ID	Analyte	Sample Location	Parameter	Sample Prep		Sample Analysis		Test	
				Date	Time	Date	Time	Results	Units
16-13152	Lead	Kitchen Sink	Drinking Water	09/20/16	14:20	09/29/16	15:33	<2.0	µg/L
16-13153	Lead	W-Wing 65 (Across from Weight Room)	Drinking Water	09/20/16	14:20	10/03/16	12:18	<2.0	µg/L
16-13154	Lead	W 65 band Room	Drinking Water	09/20/16	14:20	10/03/16	12:44	<2.0	µg/L
16-13155	Lead	E 65 (Across from Shop)	Drinking Water	09/20/16	14:20	10/03/16	12:55	<2.0	µg/L
16-13156	Lead	Facs Kitchen Sink	Drinking Water	09/20/16	14:20	10/03/16	13:14	<2.0	µg/L
16-13157	Lead	W Wing 30, Floor 1	Drinking Water	09/20/16	14:20	10/03/16	13:22	<2.0	µg/L
16-13158	Lead	Dist. Office, Floor 1	Drinking Water	09/20/16	14:20	10/03/16	13:29	<2.0	µg/L
16-13159	Lead	2nd Floor, E 30	Drinking Water	09/20/16	14:20	10/03/16	13:34	<2.0	µg/L
16-13160	Lead	W-Wing, 2nd Floor	Drinking Water	09/20/16	14:20	10/03/16	13:38	<2.0	µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L
	Lead		Drinking Water						µg/L

Approved methods used in analyzing the samples listed above have the following reporting levels:
 SM3113 - Lead, 2.0 µg / L
 Maximum contaminant levels: Lead, 15.0 µg / L

Sample Temp: 21 °C

Sample Collected by: Client ___ TCWC
 Date Reported: 10/04/16

Approved By:  
 Laboratory Manager Senior Analyst

The results listed in this report apply only to the above listed samples. All routine quality assurance procedures were followed, unless otherwise noted. This analytical report must be reported in its entirety. All methods are certified by the Minnesota Department of Health, unless otherwise noted.